



DATE: May 29, 2003

BULLETIN #: 01026

PRODUCT: EnviroAir Series

"B" Revision EnviroAir Low Ambient Kit

EMI now has low ambient kits available for the Cooling only revision "B" EnviroAir systems. The low ambient kits would allow the ECW series systems to operate down to 40 degrees Fahrenheit before a Lock Out Thermostat interrupts the "Y" or cooling signal to the compressor contactor. The revision "B" CCW condensing units now have a high side Schrader access port to allow the application of a Fan Cycling Switch. A Crankcase Heater is required and is included for low ambient operation of the CCW09 and CCW12 condensing units.

The Low Ambient Kit for the ECW9000 and ECW12000 systems is 550-1136.

The Low Ambient Kit for the ECW18000 and ECW24000 systems is 550-1137.

NOTE: If you have an ECW system "A" revision system and the CCW condenser end product number does not end in the letter "B" then the Low Ambient Kit cannot be installed. The Revision "A" EnviroAir units do not have the high side Schrader access port so the fan cycling switch cannot be installed. Please refer to the installation and wiring instructions included with the above kits for more information.